Water Valve
1 Comp (Fire
& Rec.

NOTE:
EXCAVATE 2'-3 EXT. CAP CONSIST.
STAKE 3' DEEP KNOBE HYDRANT
BACK WITH CONCRETE THRUST BLOCK

NOTE
PROVIDE 2'x3' BED OF CRUSHED STONE 3' DEEP UNDER HYDRANT. BACK WITH CONCRETE THRUST BLOCK

8"x8"x6" TEE
8"x6" REDUCER
6" GATE VALVE
HYDRANT (McAVITY M 58-M)
6" WATER VALVE
TEE HYDRANT LINES FROM LAYMOUTH TO FIRE STATION
M.H.36
M.H.38
M.H.37
FROM M.H. 34 SEE SHEET 7
TO M.H. 42 SEE SHEET 7
MAITLAND
ROAD
EXISTING CULVERT
12" CULVERT
10" SEWER
4" SEWER
8" A.C. WATER MAIN
8"x8"x6" TEE
8"x6" TEE CAPPED
TEE SIDE END BACK OF 8"x8"x6" TEE TO RECEIVE FUTURE STUB FOR FUTURE EXTENSION
HOTEL
RES.
FIRE STATION
110'
20'
40'
25'
100'
90'
84'
78'
54'

REVISIONS				STAMP
REV NO	DATE	BY	DESCRIPTION	
1	66-10-31	WNH	VERTICAL LINE ADDED	
2	66-12-07	JCT	LATERAL & DIMENSIONS REVISED	
	67-1-9	FOR	ASBUILT INFORMATION ADDED	

PROFESSIONAL ENGINEER NOVA SCOTIA

W. N. HOLLNER & ASSOCIATES
CONSULTING ENGINEERS
TRURO NOVA SCOTIA

SANITARY SEWER SYSTEM
SHUBENACADIE, N.S.
MUNICIPALITY OF EAST HANTS

DRAWN	16 JAN '67	PLAN & PROFILE MAITLAND ROAD
CHECKED	AS NOTED	
		SH 12 OF 34
		DRAWING NO 6633-12

Scale
HORIZONTAL 1"=40'
VERTICAL 1"=4'

M.H.36 STA 2+12.9
M.H.38 STA 4+50.0
M.H.37 STA 7+85.0
CULVERT
8"x8"x6" TEE
INV. ELEV 31.4'
8"x8"x6" TEE CAPPED
8"-22½° ELBOW
INV. ELEV 31.2'
8" A.C. WATER MAIN
INV. ELEV 29.3'
INV. OUT 27.5'
8" GATE VALVE
8"x6" REDUCER
6" GATE VALVE
8"x8"x6" TEE
INV. ELEV 24.2'
INV. OUT 22.4'
INV. IN 22.6'
8" CONC. C.I.
INV. ELEV 22.0'
INV. IN 22.0'
INV. OUT FROM M.H. 42 19.3'
INV. IN 19.5'
INV. IN FROM M.H. 34 19.3' SEE SHEET 7
EXISTING CULVERT
8"x8"x6" TEE CAPPED
8" CONC. C.I.
6" COPPER
INV. OUT 23.2'
TAP CAP ON END OF 8"x8"x6" TEE TO RECEIVE 1" COPPER (BY OTHERS) FOR 1" COPPER LATERAL

KEUFFEL & ESSER CO. NEW YORK
TRADE STANDARD MARK REG. U.S. PAT. OFF. PROFILE PLATE A 4 X 20 100% RAG PAPER MADE IN U.S.A.
KEUFFEL & ESSER CO. NEW YORK
TRADE STANDARD MARK REG. U.S. PAT. OFF. PROFILE PLATE A 4 X 20 100% RAG PAPER MADE IN U.S.A.
KEUFFEL & ESSER CO. NEW YORK