

Parks, Recreation & Culture

REQUEST FOR CONSTRUCTION

Mount Uniacke Library Renovations
RFC50303 - Addendum 3

Release date: August 26, 2020

Tenders will be received up to
3:00:00 pm local time on Tuesday, September 1, 2020

Contact: Michael Hatfield
Procurement Officer
Municipality of East Hants
Telephone: (902) 883-7098, Ext 232
Email: mhatfield@easthants.ca



EAST HANTS
We live it!

Contents

QUESTIONS 3



QUESTIONS

We received a couple of late questions, but have chosen to answer them as follows:

In the tender documents it states carpet tile is to be installed everywhere but the foyer (see below). Does this mean everywhere that is labeled with sq.ft. measurements (ie: 120sq.ft & 151 sq.ft) or does this mean literally the entire space other than the foyer, bathroom and “tiled area”.

Carpet tile is to be installed everywhere but the foyer (existing ceramic tile which will remain) and the area near the entrance described in the sketch which is to be vinyl planking. The preferred carpet tile is Pro Sol@utions 17525 Broadway, though East Hants will consider a similar quality, colour, and pattern of tile, provided it is acceptable to Library staff.

Carpet is to be installed in all areas shown in Exhibit 3, except:

- The foyer (shown with three doors associated with it) which has ceramic tile which will remain
- The tiled area shown on the sketch
- The washroom (which will have vinyl plank flooring installed in it)
- The storage closet, as it is out of scope. The storage closet is accessed via the door which opens onto the tiled area.

Wondering about the carpet tile for this project.

The Spec list a different color number than the picture in exhibit 1. Are you able to provide the collection that this carpet tile is from? Or the technical specification so we can see what other products would be comparable?

We understand now that the product shown in Exhibit 1 was not a carpet tile. The intent in providing the sample was to show the colours and preferred pattern of carpet tile the Library management would like to have. We recognize that the Contractor cannot predict the end-user's taste, but the end-user understands they will have to select a tile from the available range of colours. Our requirement is to provide a product line which contain similar colours and that is commercial-grade carpet tile made from 100% nylon fibre with a lifetime warranty covering, without limitation, commercial wear, static, zippering, and delamination.

END OF ADDENDUM