



### Acceptable Barrier Free Design Options

that meet the  
intent of articles  
3.8.3.6 to 3.8.3.13

### GUIDE ONLY

For full requirement  
details refer to

Nova Scotia  
Building Code  
Regulations  
2017

\* Min clearance of 1500mm x 1500mm (60"x 60") in front of stall

\* Out swinging doors to close automatically

\* Stall doors shall swing outward unless there is sufficient floor space within the stall for the door to swing inwards in addition to a clear floor space of at least 800mm x 1350mm (31 1/2" x 53")

\* L-shape grab bar to be mounted on side wall closest to water closet

\* Grab bars installed to resist a min 1.3kN (292 pound) force applied vertically or horizontally.

\* L-shape grab bar to be mounted on side wall closest to water closet.

\* Grab bars installed to resist a min 1.3kN (292 pound) force applied vertically or horizontally.  
\* Grab bars to be slip-resistant and free of any sharp or abrasive elements.  
\* Grab bars to be mounted on surfaces that are free of any sharp or abrasive elements.  
\* Grab bars shall be 30mm to 40mm (1 3/16" - 1 9/16") in diameter.

