

# Parks, Recreation & Culture

## REQUEST FOR CONSTRUCTION

Mount Uniacke Library Renovations  
RFC50303 - Addendum 2

Release date: August 24, 2020

**Tenders will be received up to**  
3:00:00 pm local time on Tuesday, September 1, 2020

Contact: Michael Hatfield  
Procurement Officer  
Municipality of East Hants  
Telephone: (902) 883-7098, Ext 232  
Email: [mhatfield@easthants.ca](mailto:mhatfield@easthants.ca)



**EAST HANTS**  
**We live it!**

# Contents

CLARIFICATIONS ..... 3



## CLARIFICATIONS

It was brought to our attention that we would not be able to achieve the 1500mm turning area required by the guidelines for an accessible washroom given the room's size.

While our intent remains to make the washroom as accessible as possible, we understand this requirement cannot be met and waive it. That said, the Contractor will still have make reasonable efforts to keep obstacles out of the turning area when making changes and to maximize the available turning area.

END OF ADDENDUM