

# Infrastructure & Operations

## REQUEST FOR CONSTRUCTION

Enfield Water Treatment Plant Capacity Upgrade - RFC50573  
Addendum 5

Release date: May 17, 2023

Proposals will be received up to  
3:00:00 pm local time on Friday, May 26, 2023

Contact: Michael Hatfield  
Procurement Officer  
Municipality of East Hants  
Telephone: (902) 883-6232  
Email: [mhatfield@easthants.ca](mailto:mhatfield@easthants.ca)



**EAST HANTS**  
We live it!

# Contents

1. Question..... 3



## 1. Question

East Hants has received the following question (**answer in red**):

1. The electrical specifications call for aluminum rigid piping. After visiting site, we noticed steel rigid is used throughout, therefore we are wondering if steel can be used instead of aluminum?

**Rigid steel conduit is acceptable.**