

# Parks, Recreation & Culture

## REQUEST FOR QUOTATIONS

Sports Court, Kiln Creek  
RFQ50773 - Addendum 1

Release date: January 15, 2025

Quotations will be received up to  
2:00:00 pm local Nova Scotia time on February 4, 2025

Contact: Michael Hatfield  
Procurement Officer  
Municipality of East Hants  
Telephone: 902-883-6232  
Email: [mhatfield@easthants.ca](mailto:mhatfield@easthants.ca)



**EAST HANTS**  
We live it!

# Contents

1. QUESTIONS ..... 3



## 1. QUESTIONS

East Hants have received the following questions:

1. Is the Contractor responsible for providing geotechnical and lab services related to compaction testing, sieve analysis, and mix design or are those services being provided by the Municipality?

The Contractor is responsible to provide these services.

2. Other than the noted generalised Type C, has the asphalt mix been specified?

No.

3. What are the planarity tolerances for the court surface?

East Hants's expectations are that the court will have a smooth, uniform surface which does not allow for standing water. Up to 1% drainage toward the swale adjacent to the Court locations is acceptable. The finished court surface is to be safe for recreational pickleball play.

4. Is consideration being given to providing for rough-in locations to accommodate lighting?

No.

5. Understanding the fencing contractor is responsible for fencing, net and basketball standards layouts, are they also responsible for survey services to locate the extents of the court area?

The Contractor under this contract is responsible for layouts for fencing, nets, and basketball standards so that the fencing contractor can install in the correct location; this would include any services related to determining these locations. The intent is to have this Contractor to work closely with East Hants' fencing company to ensure correct placement.

6. Will there be a requirement to connect any court perimeter drainage infrastructure to other similar infrastructure serving the broader site plan?

No.

7. Is the Contractor to supply the equipment for the pickleball nets and basketball standards? The RFQ states the fencing contractor is installing (2.1.2)

Supply of pickleball nets and basketball standards is not part of this contract.

END OF ADDENDUM