

# Parks, Recreation & Culture

## REQUEST FOR QUOTATIONS

Sports Court, Kiln Creek  
RFQ50773 - Addendum 3

Release date: January 22, 2025

Quotations will be received up to  
2:00:00 pm local Nova Scotia time on February 4, 2025

Contact: Michael Hatfield  
Procurement Officer  
Municipality of East Hants  
Telephone: 902-883-6232  
Email: [mhatfield@easthants.ca](mailto:mhatfield@easthants.ca)



**EAST HANTS**  
We live it!

# Contents

1. QUESTIONS ..... 3



## 1. QUESTIONS

East Hants have received the following questions:

1. Planarity specifications for acrylic sport surfaces are as listed below. Could you please request these specifications be added to the document for the asphalt sub-straight.
  - 1% cross slope for drainage across the entire surface (no crown)
  - Surface must drain within 20mins after a flood test
  - Planarity tolerances are 6mm within 4m and 3mm within 1m.

These specifications are acceptable and in accordance with the intent of Addendum 1.

2. Acrylic surfacing requires 2 lifts of asphalt, 1 base and 1 seal course. We have had no success in the past installing acrylics on 1 single lift of asphalt due to porosity and planarity.

After review of your request with independent sources, we will change the requirement to one lift of Type C at 50mm and one lift of Type D at 40mm, compacted thickness.

END OF ADDENDUM